

## FIRE RESISTANCE RATING

Testing conducted in accordance with **CAN/ULC-S101/ASTM E-119-08A**, Fire Endurance Test of Building Construction and Material.

<b>Material</b>	<b>Application Description</b>	<b>Time to Flame Through</b>
<b>3/8" OSB Sheathing</b>	CAN/ULC S101-07 Standard Method of Fire Endurance Tests of Building and Construction Materials. 3/8" OSB Sheathing coated with SafeCoat® Latex at 160 sq. feet per gallon.	<b>17 minutes</b>
<b>Floor/Ceiling Assembly with 3/4" OSB</b>	Tested in accordance with the ASTM E-119-05A Floor/Ceiling; NFPA 251-06, Small Scale Test, and CAN 4-S101-04. 2"x10" nominal SPF floor joists 16" on centre. 3/4" oriented strand board flooring. Underside assembly coated with SafeCoat® Latex at 150 sq. ft. per gallon	<b>46 minutes 37 seconds</b>
<b>Floor/Ceiling Assembly with 3/4" OSB and 5/8" Type-X Gypsum</b>	Tested in accordance with the ASTM E-119-05A Floor/Ceiling; NFPA 251-06, Small Scale Test, and CAN 4-S101-04. 2"x10" nominal SPF floor joists, 16" on centre. 3/4" oriented strand board flooring, 5/8" type X gypsum with the exposed side of the gypsum coated with SafeCoat® Latex at 150 sq. feet per gallon. There was no flame-through as the test was terminated due to heavy smoke at 1-3/4 hours.	<b>1-3/4 hour</b>
<b>Floor/Ceiling Assembly with 3/4" OSB and 24 Gauge Sheet Metal</b>	Tested in accordance with CAN/ULC S101 Closed Floor/Ceiling Assembly with 3/4" OSB and 24-Gauge Sheet Metal Ceiling coated with SafeCoat® Latex at 150 sq. ft. per gallon. Test was terminated at 60 minutes with no failure.	<b>1 hour</b>
<b>1/2" Regular Gypsum Wall Assembly</b>	Tested in accordance with CAN/ULC S101-07 Standard Test Method for Fire Tests of Building Construction and Materials. Assembly consisted of 1/2" drywall; 2x4 wood stud frame; unbacked horizontal seam taped and mudded; 3.5" thick R-12 fibreglass insulation; and SafeCoat® Latex applied at 100 sq. ft. per gallon. The assembly met burn-through and temperature rise requirements for 63 minutes.	<b>63 minutes</b>

## TEST RESULTS

### FLAME and SMOKE DEVELOPED RATING

Testing was conducted in accordance with **ASTM E84** and **CAN/ULC-S102** "Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies".

Material	Application Description	Flame Spread Rating	Smoke Developed Classification
<b>Douglas Fir Lumber</b>	<b>SafeCoat® Latex</b> at a rate of 3.7 m <sup>2</sup> /L or 150 sq. feet per gallon	<b>5</b>	<b>5</b>
<b>SPF Plywood</b>	<b>SafeCoat® Latex</b> at a rate of 3.7 m <sup>2</sup> /L or 150 sq. ft. per gallon .	<b>5</b>	<b>0</b>
<b>Oriented Strand Board</b>	OSB (11 mm nominal thickness), coated with <b>SafeCoat® Latex</b> at a rate of 3.7m <sup>2</sup> /L or 150 sq. ft. per gallon.	<b>10</b>	<b>20</b>
<b>High Density Polyurethane Foam</b>	Coated with <b>SafeCoat® Latex</b> at 80 sq. feet per gallon meets the ignition barrier. This does not qualify the product as a thermal barrier over polyurethane spray foam which is part of the Canadian code requirement for all applications. The addition of 3/8" OSB or SPF plywood coated with the SafeCoat® Latex as per above, over the spray foam would satisfy the thermal and ignition requirement.	<b>25</b>	<b>150</b>
<b>3/8" OSB Sheathing for Residential Construction. Coated boards must bear the ULC-approved stamp.</b>	Mineral & Fibre Board Listing CAN/ULC-S102 satisfies code requirements for residential construction for flame spread in Edmonton and Calgary jurisdictions for side-walls closer than 1.5 meters or outside the 10-minute response time. SafeCoat® Latex is listed and the application must also be listed. This requires the application to be done in a controlled environment by a certified applicator. Boards must bear the ULC Listed Stamp for Mineral and Fibre Boards. These boards meet the Class A Flame Spread requirement as well as the 15-Minute Fire Resistance requirement (see test below).	<b>10</b>	<b>20</b>

\*Suitable latex paints may be applied in 1 coat on the SafeCoat® Latex to achieve a different colour, sheen, or more cleanable finish or when the product will be subject to frequent cleaning. The SafeCoat® 725 is no longer manufactured.

## CERTIFICATION

Each container bears a label with the following marks:



ULC Listing number is BMQXC.R19565.